

## MARKINGS (SECTION 2-9)

**TEST M**

TEST ORDER	SECTION NO.	TESTING DESCRIPTION	WHO	DATE	RESULTS	SIGN OFF
	<b>2-9</b>	<b>Markings.</b>				
	2-9.1	Each nozzle shall be permanently identified with the following information using figures and letters not less than 3/16 in. (4.8 mm) in height:  (a) Name of manufacturer (b) Unique product or model designation (c) All other markings required by this standard	TIM	8/17/99	See artwork. Completed.	TIM
	<b>2-9.2</b>	Each spray nozzle shall be marked with the rated pressure of the nozzle	TIM	8/17/99	Completed.	TIM
	2-9.3	Each spray nozzle shall be marked with the flow rate at positions of straight stream and full spray. Select gallonage nozzles shall be marked to indicate the flow rate at each setting. Constant pressure (automatic) nozzles shall be marked with the minimum and maximum discharge as permitted in Section 2-1.	TIM	8/17/99	Completed.	TIM
	2-9.4	Nozzles equipped with a flush feature shall indicate the flush operating position with the word FLUSH.	TIM	8/17/99	Completed.	TIM
	2-9.5	Adjustable-pattern nozzles shall be marked to indicate straight stream and spray pattern settings, or arrows shall indicate the direction of adjustments for straight stream or spray pattern.	TIM	8/17/99	Completed.	TIM

NOZZLE SAMPLE INFORMATION:  
 MODEL :HMD-VPGI  
 SERIAL NUMBER: