



Certificate of Compliance

Fire Hose Nozzles

This certificate is issued for the following equipment:

QuadraFog Series Fire Hose Nozzles

Selectable gallonage type, 30, 60, 95, and 125 gpm (110, 230, 360, and 470 Lpm)

Rated service pressure of 100 psi (7 bar)

Aluminum construction

1.5, 1.75, 2.0, 2.5, or 3.0 in. (38, 44, 52, 65, or 75 mm) water inlet connection

A complete list of models is included in the latest edition
of the FM Approvals Fire Protection Approval Guide

Manufactured by:

Task Force Tips, Inc.
2800 East Evans Avenue
Valparaiso, IN 46383-6940

FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard 5511, June 2005

Project Identifier: 3028839

Date of Approval: September 12, 2007



Member of the FM Global Group

A handwritten signature in black ink, appearing to read 'Richard B. Dunne'.

Richard Dunne, Group Manager
FM Approvals – Hydraulics Group

9/12/07
Date