



Certificate of Compliance

Fire Hose Nozzles

This certificate is issued for the following equipment:

Mid-Matic Series Fire Hose Nozzles

Constant pressure type
Rated flow of 70 to 200 gpm (260 to 750 Lpm) at 100 psi (7 bar)
Aluminum construction
1.5, 2.0, or 2.5 in. (38, 52, or 65 mm) water inlet connection

**A complete list of models is included in the latest edition
of the FM Approvals Fire Protection Approval Guide**

Manufactured by:

Task Force Tips, Inc.
2800 East Evans Avenue
Valparaiso, IN 46383-6940

FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard 5511, June 2005

Project Identifier: 3028839

Date of Approval: September 12, 2007

A handwritten signature in black ink, appearing to read 'Richard B. Dunne'.

Richard Dunne, Group Manager
FM Approvals – Hydraulics Group

9/12/07
Date



Member of the FM Global Group