

# *Certificate of Conformance*

*to*

*EN15182-4 (2010) Handheld Branchpipes for Fire Service Use*

*Task Force Tips, Inc. certifies that the following nozzles meet or exceed the requirements found in the EN15182-4 (2010) standard.*

## **Ultimatic FO7 PN16/40**

*For supporting documentation contact us at [www.tft.com](http://www.tft.com)*



***TASK FORCE TIPS***

*Delivers what our customers need, when they need it.*



TASK FORCE TIPS, INC  
REGISTERED TO ISO 9001:2008  
FILE NUMBER 10001004 QM08

**Annex C**  
(normative)

**Datasheet for hand-held branchpipes for fire service use**

**C.1 General**


- NOTE 1** The symbol \* means “where applicable” in the whole datasheet  
**NOTE 2** Actual test results can be entered in the data sheet when these results exceed the minimum requirements given in this Standard

**C.2 General data**


1.1 Manufacturer	<b>Task Force Tips, Inc. – Valparaiso, IN - USA</b>
1.2 Type	<b>Ultimatic FO7 PN16/40</b>
1.3 Type according to EN 15182-1 Annex A	
1.4 Flowrate (l/min) at $p_R$	<b>220 l/min @ 6 BAR</b>
1.5 Flow settings *	<b>50-90-130-180-200</b>
1.6 Type of spray *	<b>Full Cone</b>


**C.3 Flow pressure chart**

Use the following symbols to represent different types of cone spray:



Use the following symbols to represent flow at spray types (NN represents throw in METERS):





**50 l/min**

⑫

⑨


①

**220 l/min**

③①

⑩

③



**150 l/min**

②⑧

⑩

⑤

**500 l/min**

④④

⑪

③

#### C.4 Operational devices

3.1 Fitting system	Swiveling Coupling
3.2 Gripping device	Pistol Grip
3.3 Open/shut-off device *	Slide Valve
3.4 Jet/spray system *	Rotating operating element
3.5 Flow adjustment system *	Slide Valve

#### C.5 Requirements

OPERATING AND HANDLING	Relevant sub clause number per standard	Item	Minimum Requirement	Test Result
	EN 15182-4/4.2.1	<b>Dimensions (mm)</b>	≤ 550 x 350 x 150	286 x 178 x 76
	EN 15182-4/4.2.1	<b>Mass (kg)</b>	≤ 3.5	1.5
	EN 15182-4/4.2.2	<b>Torques needed for moving operating elements (N·m)</b>		
		Valve Handle (Bale)	≤ 15	3.36
		Open Valve with Trigger	≤ 15	6.24
		Engage Trigger Lock	≤ 15	.113
		Disengage Trigger Lock	≤ 15	2.50
		Flow adjustment element	≤ 15	3.36
		Jet adjustment element	≤ 10	0.5
EN 15182-4/4.2.3	Rotating inlet element	≤ 5	0.9	
	<b>Flow adjustment *</b>			
EN 15182-4/4.2.4	Rotation from minimal to maximal flow	≤ 180°	N/A	
	<b>Jet adjustment *</b>			
	Rotation from straight jet to wide spray jet with a minimal spray angle of 100°	70° - 180°	138°	

PERFORMANCE	Relevant sub clause number per standard	Item	Minimum Requirement	Test Result
	EN 15182-4/4.3.3	Effective throw (m)	25 (PN40)	30 (PN40)
	EN 15182-2/4.3.3		35 (PN16)	44 (PN16)
		<b>Spray jet *</b>		
	EN 15182-4/4.3.4	Wide spray jet *: angle	≥ 100°	113°
	EN 15182-4/4.3.5	Narrow spray jet *: angle	≥ 30°	35°

PHYSICS	Relevant sub clause number per standard	Item	Minimum Requirement	Test Result
	EN 15182-1/7.2.2	<b>Sensitivity to frost (° C)</b>	Operational after 30 min @ (-15±2)°C	PASS
	EN 15182-1/7.2.1	<b>Sensitivity to heat (° C)</b>	Operational after 24 h @ (55±2)°C	PASS
	EN 15182-1/6.3.1	<b>Non-obstruction test (mm)</b>	4.76	PASS
	EN 15182-4/5.5	<b>Burst pressure (bar)</b>	100	PASS

### C.6 Operational extra data (no requirements)

Relevant sub clause number per standard	Item	Test Result
<b>Ageing tests</b>		
	UV test	
	Ozone test	
	Corrosion test	HARDCOAT EXCEED MILITARY SPECIFICATION MIL-A-8625F

**C.7 Data certified by \*:**

**Adam Ritchey**

**Quality Manager**

**Task Force Tips**